

280

SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA LIMITED

O/o. the Chief General Manager (Commercial),
TSSPDCL, Ground Floor, Corporate Office,
Mint Compound, Hyderabad.

Memo No. CGM (Comm)/ SE(C)/ DE(C)/ ADE-III/D.No.106/17-18, Dt:12-04-2017

Sub:- TSSPDCL - Comm Self Certification / Third Party Inspection System for
the Internal Electrical Installations upto 650V - Instructions issued - Reg.

Ref:- 1. Lr.No.CEIG/Tech/D.No.610/2017, dt. 13.03.2017.

2. GO Ms.No.12, Energy (Budget-A2)Dept., dt. 06.05.2016.

@@@

The Chief Electrical Inspector to Government of Telangana has communicated the procedure to be followed on Self Certification / Third Party Inspection System upto 650V to provide speedy processing for issue of Electrical Clearance to provide an investor friendly environment in the State of Telangana.

The Government of Telangana has issued notification vide GO Ms.No.12 Energy (Budget-A2) Dept. dated: 06.02.2016 for approval and Self Certification System notifying *"that every Electrical Installations upto 650V shall be inspected, tested and self certified by the owner of the installation / third party under regulation 30 & 43 as per Central Electricity Authority (Measures Relating to Safety and Electric Supply) Regulations, 2010"*.

In view of the above the following instructions issued:

- i) The commencement of supply or recommencement after shutdown for six months and above for the installations upto 650V shall be carried out by the supplier by accepting the self certifications / third party certification with a copy to the concerned authority of CEIG department.
- ii) It is felt necessary that such owner who certify the installation shall invariably take assistance of Chartered Electrical Safety Engineer who shall be a qualified Electrical Engineer with 5 years experience in operation and maintenance of Electrical Installation and shall also hold a Supervisor Competency Certificate issued by the Telangana Electrical Licensing Board and shall not be a whole time employee of any company of firm. Such owner shall submit the report of self certification in the Form-I and Form-II (which the copies are enclosed) to supplier as well as a copy to the concerned authority of the department.

Contd.. P.2

- iii) The CEIG department has already published the procedure for Approval and Self Certification / Third Party Inspection System upto 650V, with relevant form, i.e. Form-I&II in their website. Therefore, the supplier is also requested to publish the process of Approval and Self Certification / Third Party Inspection System upto 650V with relevant forms, Form-I&II, to enable third party verification of authenticity of Electricity Connections in their respective websites.
- iv) Under Regulation 13(4), 46(7) of Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010, owner is at all times solely responsible for the maintenance of the above installation on such condition as to be free from danger.

Hence, all the Superintending Engineers/Operation are requested to follow the above instructions scrupulously for Self Certification / Third Party Inspection System for the Internal Electrical Installations upto 650V.


Chief General Manager/Commercial

To:
All the Superintending Engineers/Operation
All the Divisional Engineers/Operation

Copy submitted to:
The Director/Commercial/TSSPDCL
The Director/Operation/TSSPDCL

Copy to:
The Chief General Manager/Operation/Metro Zone & Ranga Reddy Zone.
The DE/Tech to CMD

The General Manager/IT/TSSPDCL --- To publish the procedure for Self Certification / Third Party Inspection System upto 650 V along with relevant Form-I & II in the TSSPDCL website to enable Third Party verification of authenticity of Electricity Connections.

GOVERNMENT OF TELANGANA
A B S T R A C T

ENERGY DEPARTMENT - Electricity Act, 2003 - Central Electricity Authority (Measures relating to safety and electric Supply) Regulations, 2010- Electrical Installation upto 650V - Self-Certification - Notification- Orders Issued.

ENERGY (BUDGET.A2) DEPARTMENT

G.O.MS.No. 12

Dated: 06/05/2016
Read:

From the CEIG Lr.No.CEIG/TS/TS-iPASS/D.No.1010/2016, Dated:30.04.2016.

ORDER :

Government of Telangana has enacted Telangana State Industrial Project Approval and Self Certification System - TS-i PASS Act 3 of 2014 to provide speedy processing for issue of various clearances, licences and certificates required for setting up industries and also to provide an investor friendly environment in the State of Telangana.

2. In the circumstances reported by the Chief Electrical Inspector, the Government after careful examination of the matter as regards to issue the self-certification by the owner in detail to encourage Electrical Installation having voltage upto 650 V as per regulation 30 and 43 of Central Electricity Authority (Measures relating to safety and electric Supply) Regulations, 2010 and decided to issue the following Notification to that effect.

3. Accordingly, the following Notification shall be published in the extraordinary issue of Telangana Gazette.

NOTIFICATION

In exercise of the powers conferred by sub section (1) of section 162 of The Electricity Act, 2003 and regulation 43 and 30 of Central Electricity Authority (Measures relating to safety and electric Supply) Regulations, 2010 as amended from time to time, the State Government hereby notifies that, every electrical installation upto 650V shall be inspected, tested and self- certified by the owner of the installation before commencement of supply or recommencement after shut down for six months and above for ensuring observance of safety measures specified under said regulations and such owner shall submit the report of self-certification in the Form-I or Form-II, as the case may be , Schedule - IV to the Electrical Inspector.

2. Provided further that every electrical installation covered under section 54 of the Electricity Act, 2003 shall be inspected and tested by the Electrical Inspector.

p.t.o.

3. The Chief Electrical Inspector to Government of Telangana, Hyderabad shall take further action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF TELANGANA)

ARVIND KUMAR,
Principal Secretary to Government (FAC)

To
The Commissioner of Printing and Stationery, Hyderabad
(With a requested to publish the G.O in the extraordinary issue of
Telangana Gazette and supply 100 copies to this Department)
The Chief Electrical Inspector to Govt. of Telangana, Hyderabad

Copy to:
The P.S. to Hon'ble Minister (Energy)
The P.S. to Prl. Secretary (Energy)
File (C.No.470/Budget/2016)
SC/SF.

//Forwarded :: By Order//

SECTION OFFICER